

APPENDIX - VIII

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 4882493-2026

Date : 19/06/2026

It is certified that an inspection team headed by Rakhi-S.R
Public health Inspector, grade-II (Name of Officers
with designation) from Health Section (Thrissur corporation) (Name of
Department/Office) inspected the ST Jude public school
Kuttanellur, Elamthuruthy, Thrissur, 680014 (Name & Address of
the School) on 19/06/2026 and found that the ST Jude public school
ST Jude public school (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.


The above valid for a period of 2026-2027.


RAKHI S. R.
PUBLIC HEALTH INSPECTOR-II
THRISSUR CORPORATION

Signature with Seal : Karthika C

Name : Karthika C

Designation : SBHI II


Karthika C.
Senior Public Health Inspector-Gr II
Thrissur Corporation Circle / Zonal
Thrissur Corporation

To

ST Jude public school
Kuttanellur P.O
Elamthuruthy, 680014

(Name & Address of the Institution)

Philomena

PRINCIPAL
ST. JUDE PUBLIC SCHOOL
KUTTANELLUR P.O, THRISSUR-680 014

Manoj M J
MANAGER
ST. JUDE PUBLIC SCHOOL
KUTTANELLUR, THRISSUR-14



UbiC Envirocare Lab

TEMPLE TREES, GROUND FLOOR, OPP. CANARA BANK, PAZHAYANADAKKAVU ROAD, THRISSUR-680001

Ph. 0487 2997288, Mob: 9037555789 E-mail - ubicenvirocare@yahoo.com

State Pollution Control Board Approval No. PCB/LAB/44/2007

ANALYSIS REPORT

Sample no : - UL/003
Sample name : - Well Water
Sample submitted by : - Aqua world
Standard referred by : - IS:10500:2012

Sample Receipt : - 07.06.2026
Date of Issue : - 10.06.2026

PCB Approval No. : - PCB/LAB/44/2007

To
ST. JUDE PUBLIC SCHOOL
KUTTANELLUR
THRISSUR

Sl. No	Parameters tested	Unit	Method of Test	Results	Acceptable Limit as per IS:10500-2012
PHYSICAL EXAMINATION					
1.	Colour	Hazens	IS:3025(4) - R.2021	1	5
2.	Taste & Odour	--	IS:3025(5) - 2018	Agreeable	Agreeable
3.	Turbidity	NTU	IS:3025(10) - R.2023	0.1	1 NTU
4.	Electrical Conductivity	µs/cm	IS:3025(14) - 2013 (R.2023)	150µs/cm	---
5.	Total Dissolved Solids	Mg/l	IS:3025(16) - R.2023	90	500 Mg/l
CHEMICAL EXAMINATION					
6.	Ph	pH unit	IS:3025(11) - R.2022	7.2	6.5 - 8.5
7.	Iron(as Fe)	Mg/l	IS:3025(53) - R.2024	0.03	1.0 Mg/l
8.	Total Alkalinity(as CaCO ₃)	Mg/l	IS:3025(23) - R.2023	45	200 Mg/l
9.	Chloride(as Cl)	Mg/l	APHA 4500 Cl - B	Nil	250 Mg/l
10.	Residual chlorine	Mg/l	IS:3025(26) - 1986(R.2021)	Nil	0.2 Mg/l
11.	Acidity	Mg/l	IS:3025(22) - R.2024	Nil	---
12.	Silica	Mg/l	APHA 4500 - Si O ₂ A	Nil	-
13.	Fluoride(as F)	Mg/l	APHA 4500-F - D	Nil	1.0 Mg/l
14.	Total Hardness(as CaCO ₃)	Mg/l	IS:3025(21) - R.2023	48.9	200 Mg/l
15.	Calcium(as Ca)	Mg/l	IS:3025(40) - R.2024	10.3	75 Mg/l
16.	Magnesium(as Mg)	Mg/l	IS:3025(46) - R.2023	6.4	30 Mg/l
17.	Sulphate(as SO ₄)	Mg/l	APHA 4500 (SO ₄ ²⁻ E)	1.02	200 Mg/l
18.	Nitrate (as NO ₃)	Mg/l	APHA 4500 NO ₃ -B	Nil	45 Mg/l
BACTERIOLOGICAL ANALYSIS -MPN Method					
19.	No. of E.coli/100ml	IS:15185:2016 - R.2021	Nil/100ml	Shall not detectable in any 100ml sample	
20.	Coliforms		Nil/100ml		

The Report is of the sample tested only and shall not be reproduced except in full

REMARKS -: Tested parameters are within the standards

CHEMIST

Manager
ST. JUDE PUBLIC SCHOOL
KUTTANELLUR, THRISSUR

Principal

APPROVED BY KERALA STATE POLLUTION CONTROL BOARD
KUTTANELLUR P.O., THRISSUR-680 014